



WILLIAMSON COUNTY

Leslie Mitchell, CPPO, CPPB
1320 West Main Street, Suite 130
Franklin, Tennessee 37064
(615) 790-5868
lesliem@williamson-tn.org

November 17, 2014

Addendum #2 to Cooling Tower Bid
Bid Opening Date November 20, 2014, 2:00 p.m.

The following are questions that were received after receipt of Addendum 1, and Williamson County's responses, regarding the above bid:

Q. On the addendum you have requested manual bypass controls and then chose temperature controls . I just want to inform you that with manual bypass maintenance personnel would turn a lever by hand for the bypass. The temperature control or on/off switch would only take place if you choose automatic controls.

A. Installation to have by-pass valving in boiler room to section off supply and return to boiler.

Tower temp controls to be fan controls on each motor driven by variable temp set point, and basin pump.

Alternate is frequency drives on fans with modulating temp.

There will be no 3 way used to control temp.

Leslie Mitchell, CPPO, CPPB, Purchasing Agent

LM/lw